

UNLESS OTHERWISE SPECIFIED ON THE PLANS, MEET EXISTING GRADE AT PAVEMENT SEAM AND BOTTOM FACE OF CURB

2" BITUMINOUS CONCRETE TYPE 6 F2 (NYS DOT ITEM NO. 403.178202) TOP COURSE

CAP SEAM WITH HOT ASPHALT CONCRETE (AC) SEALANT (i.e. MISCELLANEOUS ASPHALT CEMENT, NYSDOT ITEM NO. 618.07)

EXISTING PORTLAND CEMENT CONCRETE OR ASPHALT CONCRETE PAVEMENT SECTION DEPTH VARIES

CAST-IN-PLACE CONCRETE CURB OR MONOLITHIC CURB AND SIDEWALK (WHEN SIDEWALK DIRECTLY ABUTS A ROADWAY). REFER TO PERTINENT VILLAGE STANDARD CONSTRUCTION DETAILS.

REFER TO DRAWINGS FOR FINISHED GRADE

VARIES

18" MAX.

8"

EXISTING PAVEMENT

AT SAWCUT LINES, APPLY TACK COAT (NYS DOT ITEM NO. 407.0101) ALONG VERTICAL FACE OF JOINT BETWEEN EXISTING AND NEW ASPHALT CONCRETE PAVEMENT

8" THICK NYSDOT CLASS 'D' CONCRETE (4,000 PSI) (NYS DOT ITEM NO. 608.01)

4" THICK 3/4" APPROVED COMPACTED CLEAN WASHED CRUSHED STONE BASE COURSE (PERMEABLE DRAINAGE LAYER) (NYS DOT ITEM NO. 623.12, SIZE DESIGNATION 2)

8" SUBBASE COURSE TYPE 4, OPTION D (NYS DOT ITEM NO. 304.14) FOUNDATION COURSE

APPROVED COMPACTED SUBGRADE

NOTES:

- UNLESS OTHERWISE NOTED, PORTLAND CEMENT CONCRETE SIDEWALKS SHALL MEET THE SPECIFICATIONS OUTLINED IN SECTION 501, 608 AND SUBSECTION 700 OF THE NEW YORK STATE DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS, DATED JANUARY 9, 2014 WITH LATEST REVISIONS.
- THE GENERAL CONSTRUCTION DETAILS FOR MANUFACTURING AND TRANSPORTING CONCRETE SHALL MEET THE REQUIREMENTS OF SECTION 501, PORTLAND CEMENT CONCRETE- GENERAL.
- THE VERTICAL FACE OF THE COLD BUTT JOINT BETWEEN EXISTING AND PROPOSED PAVEMENT SHALL BE SEALED WITH TACK COAT AND THE SEAM SHALL BE SEALED WITH HOT AC SEALANT AS SHOWN ABOVE.

VILLAGE OF MAMARONECK
STANDARD CONSTRUCTION DETAILS

PREPARED IN THE
OFFICE OF THE
VILLAGE ENGINEER

**PAVEMENT REPLACEMENT FOR
MONOLITHIC OR CAST-IN-PLACE
CONCRETE CURB INSTALLATION**

DESIGNED BY: ARC, PE CHECKED BY: ARC, PE
DRAWN BY: ARC, PE VOM Pavement Replacement w



VILLAGE OF MAMARONECK
VILLAGE MUNICIPAL BUILDING
169 MT. PLEASANT AVENUE (3RD FLOOR)
WESTCHESTER COUNTY
VILLAGE OF MAMARONECK, NY 10543
PHONE: (914) 777-7731
FAX: (914) 777-7792

PROJECT: DETAILS
SCALE: NOT TO SCALE
DATE: 03/13/2014

SD-6B